

Indoor Air Quality (IAQ) - Mold Report

Dana Street Elementary School
50 Dana Street
Kingston, PA, 18704



ENVIRONMENTAL ABATEMENT ASSOCIATES, INC.

December 16th, 2024

CONTENTS

Indoor Air Quality Inspection / Testing Report

Dana Street Elementary
50 Dana Street Kingston
PA, 18704

	Page
1.00 INTRODUCTION AND BACKGROUND	1
2.00 EVALUATION STRATEGY	2
3.00 DISCUSSION AND CONCLUSIONS.....	3-4

APPENDIX

MOLD AIR SAMPLE ANALYSIS RESULTS ACCREDITATIONS

"This document was prepared and created by Environmental Abatement Associates, Inc. and contains confidential, proprietary and/or privileged information that is legally protected. The document is intended for the sole use of the addressee indicated above. You are hereby notified that any use of the contents of this document or any action to inform another of its contents is strictly prohibited without first securing the written consent of Environmental Abatement Associates, Inc."

INDOOR AIR QUALITY INSPECTION / TESTING REPORT

Prepared for:

David Cordes

For the properties known as:

50 Dana Street
Kingston, PA, 18704

This Indoor Air Quality Inspection / Testing report prepared by Environmental Abatement Associates, Inc. is based on information supplied by the client and on conditions readily observable or measurable on the date of this study. Any inspection and/or testing conducted by Environmental Abatement Associates, Inc. is not meant to determine whether a building is safe or unsafe for occupants in regards to indoor air quality. Interior building conditions vary constantly, therefore the findings and results presented in this report should be considered relative to and representative of the conditions that existed at the time of the inspection and testing. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries or losses. These services are a supplement to, and not a substitute for, the client's responsibility for protecting the health and safety of employees, students, residents and others and for complying with applicable laws and regulations. Environmental Abatement Associates, Inc. warrants that its work is performed in a competent and professional manner. No other warranties are expressed or implied.

1.0 INTRODUCTION AND BACKGROUND

Personnel of ENVIRONMENTAL ABATEMENT ASSOCIATES, INC. (EAA) were on site Thursday, December 5th 2024 at 50 Dana Street, Kingston, Pennsylvania to conduct an Indoor Air Quality (IAQ) inspection and testing. The inspection and testing was conducted at the request of David Cordes

2.0 EVALUATION STRATEGY

The general strategy employed in this evaluation was to:

1. CONDUCT A VISUAL INSPECTION IN DESIGNATED AREAS.
2. CONDUCT MOLD AIR SAMPLING IN DESIGNATED AREAS.
3. PROVIDE A REPORT OF FINDINGS AND RECOMMENDATIONS.

A visual inspection was conducted in designated areas. The inspection was not intended to be an intensive and detailed inspection, but rather an overview of the conditions that may cause poor indoor air quality. The condition of walls, floor, ceilings, etc. were examined for mold growth and any potential problems that could initiate mold growth were noted.

A total of four (4) mold air the samples were collected on interior of buildings using Allergenco-D sampling cassettes manufactured by Environmental Monitoring Systems and a high volume air sampling pump. One (1) air sample was also collected outside the back door in order to establish a background to be used when interpreting the results of the indoor air samples. Per manufacturer recommendations, each air sample was collected at a flow rate of fifteen (15) liters of air per minute (L/M) for a period of five (5) minutes.

Air samples were logged, labeled and shipped overnight to EMSL Analytical, Inc., an American Industrial Hygiene Association (AIHA) accredited microbiology laboratory, for analysis by microscopic examination.

INDOOR AIR QUALITY
AIR CONTAMINANT STANDARDS/GUIDELINES

AIR CONTAMINANT STANDARDS AND GUIDELINES

In parts per million (ppm)

MEASURED PARAMETER	OSHA PEL Occupational Safety and Health- Permissible Exposure Limits	ACGIH TLV American Conference of Governmental Industrial Hygienists- Threshold Limit Values		NIOSH REL National Institute for Occupational Safety and Health- Recommended Exposure Limits				ASHRAE American Society of Heating, Refrigerating and Air-Conditioning Engineers
	TWA (8) Total Weighted Average	TWA (8) Total Weighted Average	STEL Short Term Exposure Limits	TWA (8) Total Weighted Average	STEL Short Term Exposure Limits	C Ceiling Recommended Exposure Limits	IDLH Immediately Dangerous to Life and Health	RECOMMENDATIONS
Carbon Monoxide	50	25	-	35	-	200	1,200	Maximum allowable concentration for indoor living spaces is 9 ppm
Carbon Dioxide	5,000	5,000	30,000	5,000	30,000	-	40,000	< 700 ppm above outdoor level indicates adequate ventilation
Temperature								68 °F - 75 °F (winter) 73 °F - 79 °F (summer)
Relative Humidity								30% – 60%

DATA TABLE I
Temperature, Relative Humidity, Carbon Dioxide and Carbon Monoxide Readings

Test No.	Floor	Location	Test Time	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (PPM)	Carbon Monoxide (PPM)	Comments
1	1	Main Hall	7:51	69	32	605	0.7	Air sample #5871153
2	1	Art Room	7:57	75	38	724	0.7	Air sample #5871232
3	1	Cafeteria	8:03	70	37	752	0.7	Air sample #5871222
4	1	Upstairs Hall	8:08	71	30	740	0.7	Air sample #5871220
5	1	Baseline (outside)	8:21	31	20	574	0.7	Air sample #5871217

3.0 DISCUSSION AND CONCLUSIONS

Molds are part of the natural environment and are simple, microscopic organisms whose purpose is to break down dead materials. Molds can be found on plants, dry leaves, and about every other organic material. Mold spores are lightweight and are spread by air currents. If spores land on a suitable surface, they will begin to grow. In order to thrive, mold requires four things to grow: water, organic materials, oxygen, and a temperature between 40-90 degrees Fahrenheit.

To stop the growth of mold, find and stop the moisture source. Mold spores will not grow if moisture is not present.

1. Aspergillus Penicillium

a. Aspergillus species are filamentous fungi that are commonly found in soil, decaying, vegetation, seeds and grains where they thrive as saprophytes. Aspergillus species can occasionally be harmful to humans. In humans, Aspergillus fumigatus is the most common and life-threatening airborne opportunistic fungal pathogen, which is particularly important among immunocompromised hosts. Inhaling Aspergillus fumigatus spores (conidia) into the lungs may cause multiple diseases, which depend on the immunological status of the host in humans. These diseases include invasive pulmonary aspergillosis, aspergilloma, and different forms of hypersensitivity, pneumonitis, and allergic bronchopulmonary aspergillosis (ABPA).

2. Cladosporium

a. Most kinds of Cladosporium are not dangerous to humans, but sometimes they may lead to allergies, or they may worsen asthma. In worse cases, Cladosporium may lead to infections. In most cases if you open some windows or install a heat recovery ventilator (HRV). These measures will help stop new mold from forming, but will not kill active Cladosporium spores already there. For that you will need a non-toxic registered fungicide such as Concrobium.

3. Basidiospores

a. Inhalation of basidiospores can have health effects ranging from pneumonia-like symptoms to cryptococcus meningitis if the infection isn't treated before it spreads to the brain. The list of environments in which this class of molds thrives is extensive. Sources range from old fruit to damp acrylic painted walls. Detection of Basidiospores at levels higher than 5,000 count per cubic meter are considered problematic.

4. Ascospores

a. This group contains potential opportunistic pathogens, toxin producers, and allergens depending on the genus and species. Ascospores do present a human health risk but few have been reported to cause disease.

All sample locations came back with very low numbers

These findings indicate that mold remediation is not needed.

Respectfully Submitted,

Russ Bigus, M.S., Biology
Professor of Microbiology

Mold Air Sample Analysis Results



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Microbiology Chain of Custody Form

EMSL Order Number / Lab Use Only

182405426

Plymouth Meeting, PA 19462

PHONE: (610) 828-3102

EMAIL: plymouthmeetinglab@er

If BA-To is the same as Report-To leave this section blank Third-party billing requires written authorization.

Customer Information	Customer ID:	Billing ID:
	Company Name: Environmental Abatement Associates, Inc.	Company Name: Environmental Abatement Associates, Inc.
	Contact Name: Christopher Tsioles	Billing Contact: Christopher Tsioles
	Street Address: 239 Schuyler avenue suite 125B	Street Address: 239 Schuyler avenue suite 125B
	City, State, Zip Code: KINGSTON PA 18704 Country US	City, State, Zip Code: KINGSTON PA 18704 Country: US
	Phone: 570-283-0500	Phone: 570-283-0500
Email(s) for Report: eaawdt@verizon.net		Email(s) for Invoice:

Project Information

Project Name/No. 24-44.5 WWV Dana Street Elementary	Purchase Order
EMSL LIMS Project ID. (If applicable, EMSL will provide)	State of Connecticut (CT) must select project location:
State Samples PA	<input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-taxable)
Zip Code 18704	
Sampled By Name: Christopher Tsioles	Sampled By Signature
	No. of Samples in Shipment 5

Sterile, Sodium Thiosulfate Preserved Bottle Used: ☐

Biocide Used in Source (specify)

Public Water Supply Samples: ☐

Note: All results may automatically be reported to DOH if required by State.

Turn-Around-Time (TAT)

Please call ahead for large projects and/or turnaround times 6 Hours or Less. 32 Hour TAT available for select tests only. Samples must be submitted by 11:30am.

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☒ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☐ 2 Week

MICROBIOLOGY TEST CODES

M001 Air-O-Cell	M174 MoldSnap	M009 Bacteria Culture Gram Stain & Count	M115 Sewage Screen - Water (P/A**)
M030 MICRO 5	M032 Allergenco-D	M010 Bacteria Count & ID - 3 Most Prominent	M116 Sewage Screen - Water (MPN**)
M041 Fungal Direct Examination		M011 Bacteria Count & ID - 5 Most Prominent	M117 Sewage Screen - Swab (P/A**)
M169 Pollen ID & Enumeration		M012 Pseudomonas aeruginosa (P/A**)	M013 Sewage Screen - Swab (MFT*)
M005 Viable Fungi-Air Samples (Genus ID & Count)		M024 Pseudomonas aeruginosa (MFT*)	M730 Methicillin-resistant Staph aureus (MRSA)
M006 Viable Fungi-Air Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M015 Heterotrophic Plate Count	M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration
M007 Culturable Fungi-Surface Samples (Genus ID & Count)		M017 Total Coliform & E Coli (Colilert P/A**)	M014 Endotoxin Analysis
M008 Culturable Fungi-Surface Samples (Includes Penicillium, Aspergillus, Cladosporium, Stachybotrys Species ID & Count)		M018 Total Coliform & E Coli (MFT*)	M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)
M280 Dust Characterization Level-1		M114 Total Coliform & E Coli Enumeration (Colilert MPN**)	M095 Bacteroides
M281 Dust Characterization Level-2		M019 Fecal Coliform (MFT*)	Other - See Analytical Price Guide for Test Code
Add On to Spore Trap & M041 Analyses		M020 Fecal Streptococcus (MFT*)	Legionella Analysis Please use EMSL Legionella COC
available at certain lab locations		M029 Enterococci (MFT)	
M280A Dust Characterization Level-1		M129 Enterococci (Enterolert P/A**)	*MFT = Membrane Filtration Technique
M281A Dust Characterization Level-2		M180 Real Time qPCR-ERMI 36 Panel	**MPN = Most Probable Number
		M025 Sewage Screen - Water (MFT*)	***P/A = Presence/Absence

Sample #	Sample Location/Description	Sample Type (Matrix)	Potable / Non-Potable (Only for Water)	Test Code	Volume/Area	Date / Time Collected	Temperature (Lab Use Only)
Example: Sample 1	Kitchen	Water	Potable	M017	1,000 ml	1/1/2024 3:30pm	
5871253	main hall	Air		M001	1,500 ml	12/5/24 7:56AM	
5871232	art room	Air		M001	1,500 m	12/5/24 8:02AM	
5871222	cafeteria	Air		M001	1,500 m	12/5/24 8:08AM	
5871220	upstairs hall	Air		M001	1,500 m	12/5/24 8:13AM	
5871217	baseline (outside)	Air		M001	1,500 m	12/5/24 8:26AM	

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Method of Shipment:	Sample Condition Upon Receipt:	Received on Ice? <input type="checkbox"/>
Relinquished by: Christopher Tsioles	Date/Time: 12/6/24	Received by: <i>Shirleya Nicholson</i>
Relinquished by:	Date/Time:	Received by:
		Date/Time: 12-11-24

Controlled Document - COC-34 Micro R16 11/25/2023

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462

Tel/Fax: (610) 828-3102 / (610) 828-3122

<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182405426

Customer ID: ENVA55

Customer PO:

Project ID:

Attention: Christopher Tsoles
Environmental Abatement Associates, Inc.
239 Schuyler avenue suite 125B
KINGSTON, PA 18704

Phone: (570) 283-0500
Fax: (570) 283-0577
Collected Date: 12/05/2024
Received Date: 12/11/2024
Analyzed Date: 12/12/2024

Project: 24-44.5 WVV DANA STREET ELEMENTARY

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182405426-0001			182405426-0002			182405426-0003		
Client Sample ID:	5871253			5871232			5871222		
Volume (L):	150			150			150		
Sample Location:	MAIN HALL			ART ROOM			CAFETERIA		
Spore Types	Raw Count†	Count/m³	% of Total	Raw Count†	Count/m³	% of Total	Raw Count†	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium++	1	20	33.3	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	2	40	66.7	1	20	100	1	20	100
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	3	60	100	1	20	100	1	20	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	21	-	-	21	-	-	21	-
Analyt. Sensitivity 300x	-	7*	-	-	7*	-	-	7*	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

† Due to method stopping rules, extrapolated raw counts are reported in parenthesis.

No discernable field blank was submitted with this group of samples.

Kevin Ream, Laboratory Manager
or other Approved Signatory

EMSL Analytical, Inc. maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. EMSL Analytical, Inc. bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Skin Fragment and Fibrous Particulate ratings are based on the percent of non-fungal material they represent: 1 (1-25%), 2 (26-50%), 3 (51-75%), or 4 (76-100%). Background ratings are based on the total area covered by non-fungal particles: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-99%), or 5 (100%; overloaded). High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts >= 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/13/2024 07:49 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462

Tel/Fax: (610) 828-3102 / (610) 828-3122

<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182405426

Customer ID: ENVA55

Customer PO:

Project ID:

Attention: Christopher Tsoles
Environmental Abatement Associates, Inc.
239 Schuyler avenue suite 125B
KINGSTON, PA 18704

Phone: (570) 283-0500
Fax: (570) 283-0577
Collected Date: 12/05/2024
Received Date: 12/11/2024
Analyzed Date: 12/12/2024

Project: 24-44.5 WVV DANA STREET ELEMENTARY

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182405426-0004	182405426-0005	
Client Sample ID:	5871220	5871217	
Volume (L):	150	150	
Sample Location:	UPSTAIRS HALL	BASELINE (OUTSIDE)	
Spore Types	Raw Count†	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-
Ascospores	-	-	-
Aspergillus/Penicillium++	-	-	-
Basidiospores	-	-	-
Bipolaris++	-	-	-
Chaetomium++	-	-	-
Cladosporium	-	-	-
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium++	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Total Fungi	-	None Detected	-
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	21	-
Analyt. Sensitivity 300x	-	7*	-
Skin Fragments (1-4)	-	2	-
Fibrous Particulate (1-4)	-	1	-
Background (1-5)	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

† Due to method stopping rules, extrapolated raw counts are reported in parenthesis.

No discernable field blank was submitted with this group of samples.

Kevin Ream, Laboratory Manager
or other Approved Signatory

EMSL Analytical, Inc. maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. EMSL Analytical, Inc. bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Skin Fragment and Fibrous Particulate ratings are based on the percent of non-fungal material they represent: 1 (1-25%), 2 (26-50%), 3 (51-75%), or 4 (76-100%). Background ratings are based on the total area covered by non-fungal particles: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-99%), or 5 (100%; overloaded). High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts >= 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/13/2024 07:49 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

Accreditations



AIHA Laboratory Accreditation Programs, LLC

acknowledges that

EMSL Analytical, Inc.

5221 Militia Rd., Plymouth Meeting, PA 19462

Laboratory ID: LAP-178659

along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs (AIHA LAP), LLC accreditation to the ISO/IEC 17025:2017 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

LABORATORY ACCREDITATION PROGRAMS



INDUSTRIAL HYGIENE

Accreditation Expires: September 01, 2023



ENVIRONMENTAL LEAD

Accreditation Expires:



ENVIRONMENTAL MICROBIOLOGY

Accreditation Expires: September 01, 2023



FOOD

Accreditation Expires:



UNIQUE SCOPES

Accreditation Expires:

Specific Field(s) of Testing (FoT)/Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful on-going compliance with ISO/IEC 17025:2017 and AIHA LAP, LLC requirements. This certificate is not valid without the attached Scope of Accreditation. Please review the AIHA LAP, LLC website (www.aihaaccreditedlabs.org) for the most current Scope.

Cheryl O Morton

Managing Director, AIHA Laboratory Accreditation Programs, LLC



AIHA Laboratory Accreditation Programs, LLC

SCOPE OF ACCREDITATION

EMSL Analytical, Inc.

5221 Militia Rd., Plymouth Meeting, PA 19462

Laboratory ID: LAP-178659

Issue Date: 08/31/2021

The laboratory is approved for those specific field(s) of testing/methods listed in the table below. Clients are urged to verify the laboratory's current accreditation status for the particular field(s) of testing/Methods, since these can change due to proficiency status, suspension and/or withdrawal of accreditation.

Environmental Microbiology Laboratory Accreditation Program (EMLAP)

Initial Accreditation Date: 09/01/2019

EMLAP Scope Category	Field of Testing (FOT)	Component, parameter or characteristic tested	Method	Method Description (for internal methods only)
Fungal	Air - Direct Examination	Spore Trap	MICRO-SOP-201	Standard Operating Procedure for the Analysis of Airborne Fungal Spores, Hyphal Fragments, Pollen, Insect Fragments, Skin Fragments and Fibrous Particulate by Optical Microscopy of Spore Trap Samples
Fungal	Bulk - Direct Examination	Bulks (liquid or solid)	MICRO-SOP-200	Standard Operating Procedure for the Microscopic Examination of Fungal Spores, Fungal Structures, Hyphae, Pollen, Insect Fragments, and Fibrous Particulate from Surface Samples
Fungal	Surface - Direct Examination	Swab or Tape Lift	MICRO-SOP-200	Standard Operating Procedure for the Microscopic Examination of Fungal Spores, Fungal Structures, Hyphae, Pollen, Insect Fragments, and Fibrous Particulate from Surface Samples

A complete listing of currently accredited EMLAP laboratories is available on the AIHA LAP, LLC website at: <http://www.aihaaccreditedlabs.org>